

CERTIFICATE OF CONFORMITY

CERTIFICATO DI CONFORMITÀ

Issued to: SUNWAY SOLAR CO., LTD.
Rilasciato a: Building 7, Cross-border E-commerce Supervision Zone, Huguang Road, Shushan District, Hefei City, Anhui Province, China

For the product: On-Grid PV Inverter
Tipo prodotto:

Trade name:  **SUNWAYTECH**
Marchio:

Type/Model: SW3KTL3-EU, SW4KTL3-EU, SW5KTL3-EU, SW6KTL3-EU, SW8KTL3-EU,
Riferimento modello: SW10KTL3-EU, SW12KTL3-EU, SW13KTL3-EU, SW15KTL3-EU, SW17KTL3-EU, SW20KTL3-EU, SW25KTL3-EU

Ratings: See Annex
Dati di targa:

Manufactured by: SUNWAY SOLAR CO., LTD.
Costruttore: Building 7, Cross-border E-commerce Supervision Zone, Huguang Road, Shushan District, Hefei City, Anhui Province, China

Requirements: CEI 0-21:2022-03
Requisiti: *Regola tecnica di riferimento per la connessione di Utenti attivi e passivi alle reti BT delle imprese distributrici di energia elettrica*

The tested models are suitable for installation in systems with a total power greater than 11.08 kW.
I modelli testati sono adatti per l'installazione in sistemi con potenza di uscita maggiore di 11.08 kW.
This Test Certificate is granted on account of an examination by DEKRA, the results of which are laid down in a confidential file no. 6174407.50
Il presente certificato è rilasciato a causa di un esame da parte di DEKRA, i cui risultati sono riportati in un file riservato n. 6174407.50

The examination has been carried out on one single specimen or several specimens of the product, submitted by the manufacturer. The certificate does not include an assessment of the manufacturer's production. Conformity of his production with the specimen tested by DEKRA is not the responsibility of DEKRA.
Il sottoscritto dichiara che il prodotto di cui sopra è conforme ai requisiti tecnici menzionati. Questo attestato di conformità è rilasciato sulla base dei risultati di prova riferiti nel rapporto sopra menzionato.
La valutazione non include una verifica della produzione di serie né del luogo di produzione.
This Test Certificate expires at the latest on 2029-02-29 or expires upon withdrawal of one of the above mentioned standards.
Il presente certificato di prova scade al più tardi il 2029-02-29 o scade al momento del ritiro di uno dei suddetti standard.

Shanghai, 29 February 2024

Certificate Number: 6174407.01COC

DEKRA Testing and Certification (Shanghai) Ltd.


Cliff Lin
Certification Manager



© Integral publication of this certificate and adjoining reports is allowed

Accreditation of the certification body by IAS according to ISO/IEC 17065 for products.
Accreditation is valid in the areas of certification mentioned in the certificate.

PCA-141

DEKRA Testing and Certification (Shanghai) Ltd.
3F #250 Jiangchangsan Road Shibei Hi-Tech Park, 200436 Jing'an District, Shanghai, China
T +86 21 6056 7666 F +86 21 6056 7555 www.dekra-product-safety.com

Document no. : 6174407.01COC

Ratings of the testing On-Grid PV Inverter:

Valutazioni del test On-Grid PV Inverter:

Specifications table				
Model	SW3KTL3-EU	SW4KTL3-EU	SW5KTL3-EU	SW6KTL3-EU
PV input				
Max PV power (W)	5100	6000	7500	9000
Vmax PV (Vdc) (absolute Max.)	1100	1100	1100	1100
Isc PV (absolute Max.) (A)	25 x 2	25 x 2	25 x 2	25 x 2
Max. PV input current (A)	15 x 2	15 x 2	15 x 2	15 x 2
Number MPP trackers	2	2	2	2
Number input strings	1/1	1/1	1/1	1/1
MPPT voltage range (Vdc)	150-1000	150-1000	150-1000	150-1000
Vdc range @ full power (Vdc)	200-850	200-850	200-850	250-850
AC Grid (output)				
Normal AC Voltage (VAC)	3P+N+PE/3P+PE 230/400			
Frequency (Hz)	50			
Normal AC Current (A)	4.4	5.8	7.3	8.7
Max. cont. output current (A)	5.3	7	8.5	10.5
Normal Power (W)	3000	4000	5000	6000
Rated Apparent Power (VA)	3000	4000	5000	6000
Max. cont. Power (W)	3000	4000	5000	6000
Max. cont. Apparent Power (VA)	3000	4000	5000	6000
Power factor(adjustable)	1.0 (-0.8~ +0.8)			
Others				
Protective class	Class I			
Ingress protection (IP)	IP65			
Temperature (°C)	-25°C to +60°C (Derating 45°C)			
Inverter Isolation	Non-isolated			
Overvoltage category	OVC III (AC Main), OVC II (PV)			

Document no. : 6174407.01COC

Specifications table				
Model	SW8KTL3-EU	SW10KTL3-EU	SW12KTL3-EU	SW13KTL3-EU
PV input				
Max PV power (W)	12000	15000	18000	19500
Vmax PV (Vdc) (absolute Max.)	1100	1100	1100	1100
Isc PV (absolute Max.) (A)	25 x 2	25 x 2	25 x 2	25 x 2
Max. PV input current (A)	15 x 2	15 x 2	15 x 2	15 x 2
Number MPP trackers	2	2	2	2
Number input strings	1/1	1/1	1/1	1/1
MPPT voltage range (Vdc)	150-1000	150-1000	150-1000	150-1000
Vdc range @ full power (Vdc)	300-850	500-850	500-850	500-850
AC Grid (output)				
Normal AC Voltage (VAC)	3P+N+PE/3P+PE 230/400			
Frequency (Hz)	50			
Normal AC Current (A)	11.6	14.5	17.4	18.9
Max. cont. output current (A)	13.5	17	21.5	22
Normal Power (W)	8000	10000	12000	13000
Rated Apparent Power (VA)	8000	10000	12000	13000
Max. cont. Power (W)	8000	10000	12000	13000
Max. cont. Apparent Power (VA)	8000	10000	12000	13000
Power factor(adjustable)	1.0 (-0.8~ +0.8)			
Others				
Protective class	Class I			
Ingress protection (IP)	IP65			
Temperature (°C)	-25°C to +60°C (Derating 45°C)			
Inverter Isolation	Non-isolated			
Oversvoltage category	OVC III (AC Main), OVC II (PV)			

Document no. : 6174407.01COC

Specifications table				
Model	SW15KTL3-EU	SW17KTL3-EU	SW20KTL3-EU	SW25KTL3-EU
PV input				
Max PV power (W)	22500	25500	30000	37500
Vmax PV (Vdc) (absolute Max.)	1100	1100	1100	1100
Isc PV (absolute Max.) (A)	30 + 48	48 x 2	48 x 2	48 x 2
Max. PV input current (A)	20 + 32	32 x 2	32 x 2	32 x 2
Number MPP trackers	2	2	2	2
Number input strings	1/2	2/2	2/2	2/2
MPPT voltage range (Vdc)	150-1000	150-1000	150-1000	150-1000
Vdc range @ full power (Vdc)	500-850	500-850	500-850	500-850
AC Grid (output)				
Normal AC Voltage (VAC)	3P+N+PE/3P+PE 230/400			
Frequency (Hz)	50			
Normal AC Current (A)	21.8	24.7	29	36.3
Max. cont. output current (A)	27	30	32	40
Normal Power (W)	15000	17000	20000	25000
Rated Apparent Power (VA)	15000	17000	20000	25000
Max. cont. Power (W)	15000	17000	20000	25000
Max. cont. Apparent Power (VA)	15000	17000	20000	25000
Power factor(adjustable)	1.0 (-0.8~ +0.8)			
Others				
Protective class	Class I			
Ingress protection (IP)	IP65			
Temperature (°C)	-25°C to +60°C (Derating 45°C)			
Inverter Isolation	Non-isolated			
Oversvoltage category	OVC III (AC Main), OVC II (PV)			

Document no. : 6174407.01COC

Type of generating unit:

Tipologia di apparato:

Static Conversion Device <i>Dispositivo di conversione statica</i>	Interface Protection <i>Protezione di interfaccia</i>	Interface Protection Device <i>Dispositivo di interfaccia</i>	Rotating Generator Device <i>Dispositivo di generazione rotante</i>
Yes/Sì	Yes/Sì	Yes/Sì	No

REMARK: the device is capable to limit the I_{dc} to 0.5% of the nominal current

NOTA: Il dispositivo è in grado di limitare la I_{dc} allo 0.5% della corrente nominale

Firmware release (SW): V06

Revisione firmware (SW): V06

Testing Laboratory:

Laboratorio prove:

Testing Laboratory for CEI 0-21:2022-03

DEKRA Testing and Certification (Suzhou) Co., Ltd.

No. 99, Hongye Road, Suzhou Industrial Park Suzhou, 215006, P.R. China

Accreditation Number: L5313 (CNAS-ILAC)

Testing Laboratory for EMC:

1. Intertek Testing Services Shanghai

Building No.86, 1198 Qinzhou Road (North), Caohejing Development Zone, Shanghai 200233, China

Accreditation Number: 3309.02 (A2LA-ILAC)

2. Shanghai Inspection and Testing Institute of Instruments and Automation Systems Co., Ltd.

No.103, Caobao Road, Xuhui District, Shanghai, China

Accreditation Number: L0130 (CNAS-ILAC)

--- End ---